

Higgins Lake Utilities Authority (HLUA)
PO Box 437
Higgins Lake, MI 48627

Policy Number: 2024-02

New Grinder Pump Installation Policy

This policy, dated March 21, 2024, is to create a policy regarding how new grinder pumps will be installed in the HLUA sewer system, for call-outs that require repair of the grinder pump.

If the serial # starts with 7 and only the stator is being replaced, then replace stator and return to the grinder pump station.

If above is not true, then place new grinder pump in the station. Do not do any work on the old grinder pump, until we determine if we are going to keep or scrap the grinder pump.

When placing a new grinder pump in a duplex station. If serial # starts with 7 on the other grinder pump, then leave, else replace with a new grinder pump. Do not do any work on the old grinder pump, until we determine if we are going to keep or scrap the grinder pump.

It is possible that a grinder pump with a serial # that starts with 7, gets replaced with a new grinder pump. This should be rare, but possible.

Motion by: Cook, Seconded by: Gage, Roll Call Vote: Cook-Yes, Keipert-Absent, Gage-Yes, Wilson-Yes, Adopted: March 21, 2024